


[Kidde Recalls over 40 million fire extinguishers in 2017 due to failure](#)

We urge all homeowners to check their fire extinguishers to see if they are affected by the recall. Kidde makes units under many brand names. A board member checked his and two members of his family and all were affected. Kidde will replace them at no charge and provide all of the packaging to return the affected units at no cost to the owner.

FX Recall Affected Models

Determining Affected Model

Inspect your model using below diagram as a guide. Click arrows for details. If you think your model is affected, call Kidde at 855-271-0773



November 2, 2017 - In conjunction with the U.S. Consumer Product Safety Commission (CPSC), Kidde announced a recall to replace certain Kidde fire extinguishers. The replacement program was initiated because certain fire extinguishers can become clogged or require excessive force to activate, posing a risk of failure to discharge. In addition, the nozzle can detach with enough force to pose an impact hazard. The product recall involves two styles of Kidde disposable fire extinguishers: plastic handle fire extinguishers and plastic push-button fire extinguishers.

<https://www.kidde.com/home-safety/en/us/support/product-alerts/recall-kidde-fire-extinguisher/>